



---

## CERTIFICATE OF APPROVAL

### No CF 6076

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

### Profab Access LTD

Units C & D, Riversdale Road, Carlyon Road Industrial Estate,  
Atherstone, CV9 1LP

Tel: 01827 718222

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

**CERTIFIED PRODUCT**  
**1500-S Series Steel Riser**  
**Doorsets**

**TECHNICAL SCHEDULE**  
**TS30 – Industrial Type Fire**  
**Resisting Doorsets**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager



Issued: 24<sup>th</sup> February 2022  
Valid to: 23<sup>rd</sup> February 2027





---

## **CERTIFICATE No CF 6076**

### **Profab Access LTD**

---

#### **1500-S SERIES STEEL RISER DOORSETS**

1. This approval relates to the use of the 1500-S Series steel riser doorsets in providing fire resistance of 60 minutes integrity as defined in BS 476: Part 22: 1987 or BS EN 1634-1. Subject to the undermentioned conditions, the doors will meet the relevant requirements for fire resisting doorsets, for periods of up to 60 minutes (dependent upon size limitations) when used in accordance with the provisions therein.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The doors are approved on the basis of:
  - i) Initial type testing
  - ii) Audit testing at a frequency specified in TS30
  - iii) A design appraisal against TS30
  - iv) A quality management system as per ISO 9001
  - v) Inspection and surveillance of factory production control
4. This approval is applicable to latched single-acting, single and double leafed doorsets at leaf dimensions up to those given in Table 1. This approval is also applicable to the use of a "Picture" frame option and a "Beaded" frame Option. This approval is for exposure from either direction.
5. The door assemblies shall be mechanically fixed to the shaftwall supporting construction as described in the Constructional Specification.
6. This certificate does not include any approval relating to the mechanical requirements of the doors specified in TS30.
7. Doorsets shall be single-acting, single or double leaf. Double-acting doorsets are not within the scope of this approval.
8. Labels to the CERTIFIRE design referencing Profab Access Limited, CERTIFIRE and CERTIFIRE Ref. No. CF6076 and the relevant fire resistance shall be affixed to each door in the prescribed position.
9. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number (CF6076) and application where appropriate.

Signed Page 2 of 3  
E/070

Issued: 24<sup>th</sup> February 2022  
Valid to: 23<sup>rd</sup> February 2027



---

## CERTIFICATE No CF 6076

### Profab Access LTD

---

#### 1500-S SERIES STEEL RISER DOORSETS

Table 1. Maximum Permitted Door Leaf Dimensions

Doorset Configuration	Integrity (minutes)	Maximum Door Leaf Height (mm)	Maximum Door Leaf Width (mm)	Maximum Leaf Area (m <sup>2</sup> )
Latched, single-acting, single or double leaf	60	2750 (at 938mm wide)	1035 (at 2493mm high)	2.58

Unequal width double leaf doorsets are also allowable provided that the secondary leaf shall have a minimum width of 350mm and shall be a minimum of 40% the width of the primary leaf.

#### Further Information

Further information regarding the details contained in this data sheet may be obtained from Profab Access Limited (Tel: 01827 718222).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed Page 3 of 3  
E/070

Issued: 24<sup>th</sup> February 2022  
Valid to: 23<sup>rd</sup> February 2027